

.54851 1025 / (063) 281-1248 / (063) 281-1219

1.

| | | | | | |
|--|------------|--|-------------|--|-----|
| | [] () 5 | | | | |
| | | | 20-101359 8 | | () |
| | 2020-05-07 | | | | |

2.

| | | | / | | |
|---|-----------|-----|---|-----|---------------------------|
| 1 | 20-101359 | () | | | 579851 3 3 |
| 2 | 20-101360 | () | | | 585801 138-13 138-13 |
| 3 | 20-101361 | () | | | 585864 82-1 82-1 |
| 4 | 20-101362 | () | | | 585883 79-5 79-5 |
| 5 | 20-101363 | () | | 가) | 579807 6-9 6-9 |
| 6 | 20-101364 | () | | 가 | 585833 49-4 49-4 |
| 7 | 20-101365 | () | | | 579871 33-18 33-18 |
| 8 | 20-101366 | () | | () | 513884 422 () 422 () |
| 9 | 20-101367 | () | | | 585892 340-1 340-1 |

3.

| | | | | 20-101359 | 20-101360 | 20-101361 | 20-101362 |
|---|--|---------|--------|------------|------------|------------|------------|
| | | | | | | | |
| | | | 가 | | | | |
| | | | | 2020-05-07 | 2020-05-07 | 2020-05-07 | 2020-05-07 |
| | | | | | | | |
| 1 | | CFU/mL | 100CFU | 0 | 0 | 0 | 0 |
| 2 | | /100 mL | | | | | |
| 3 | | /100 mL | | | | | |
| 4 | | mg/L | 0.5 | | | | |
| 5 | | mg/L | 0.1 | 0.024 | 0.036 | 0.031 | 0.035 |
| 6 | | mg/L | 4.0 | 0.44 | 0.52 | 0.42 | 0.50 |

.54851

1025 /

(063) 281-1248 /

(063) 281-1219

| | | | | 20-101359 | 20-101360 | 20-101361 | 20-101362 |
|----|------|------|---------|------------|------------|------------|------------|
| | | | | | | | |
| | | | | 가 | | | |
| | | | | 2020-05-07 | 2020-05-07 | 2020-05-07 | 2020-05-07 |
| | | | | | | | |
| 7 | (Cu) | mg/L | 1 | | | | |
| 8 | (pH) | - | 5.8~8.5 | 6.8 | 6.8 | 6.7 | 6.7 |
| 9 | | mg/L | 3 | | | | |
| 10 | | mg/L | 250 | 12.7 | 12.8 | 12.5 | 12.9 |
| 11 | | mg/L | 0.3 | | | | |
| 12 | | mg/L | 0.05 | | | | |
| 13 | | NTU | 0.5 | 0.05 | 0.06 | 0.06 | 0.06 |

| | | | | 20-101363 | 20-101364 | 20-101365 | 20-101366 |
|----|------|---------|---------|------------|------------|------------|------------|
| | | | | | | | |
| | | | | 가 | | | |
| | | | | 2020-05-07 | 2020-05-07 | 2020-05-07 | 2020-05-07 |
| | | | | | | | |
| 1 | | CFU/mL | 100CFU | 0 | 0 | 0 | 0 |
| 2 | | /100 mL | | | | | |
| 3 | | /100 mL | | | | | |
| 4 | | mg/L | 0.5 | | | | |
| 5 | | mg/L | 0.1 | 0.029 | 0.029 | 0.021 | 0.032 |
| 6 | | mg/L | 4.0 | 0.60 | 0.43 | 0.42 | 0.44 |
| 7 | (Cu) | mg/L | 1 | | 0.055 | 0.105 | |
| 8 | (pH) | - | 5.8~8.5 | 6.7 | 6.7 | 6.7 | 6.8 |
| 9 | | mg/L | 3 | | | | 0.003 |
| 10 | | mg/L | 250 | 13.0 | 12.9 | 12.4 | 12.5 |
| 11 | | mg/L | 0.3 | | | | |
| 12 | | mg/L | 0.05 | | | | |



한국수자원공사
Korea Water Resources Corporation

20-101359 8

3/4

.54851

1025 /

(063) 281-1248 /

(063) 281-1219

| | | | | 20-101363 | 20-101364 | 20-101365 | 20-101366 |
|----|--|-----|-----|------------|------------|------------|------------|
| | | | | | | | |
| | | | 가 | | | | |
| | | | | 2020-05-07 | 2020-05-07 | 2020-05-07 | 2020-05-07 |
| | | | | | | | |
| 13 | | NTU | 0.5 | 0.05 | 0.06 | 0.06 | 0.05 |

| | | | | 20-101367 | | | |
|----|------|---------|---------|------------|---|---|---|
| | | | | | | | |
| | | | 가 | | | | |
| | | | | 2020-05-07 | | | |
| | | | | | | | |
| 1 | | CFU/mL | 100CFU | 0 | - | - | - |
| 2 | | /100 mL | | | - | - | - |
| 3 | | /100 mL | | | - | - | - |
| 4 | | mg/L | 0.5 | | - | - | - |
| 5 | | mg/L | 0.1 | 0.039 | - | - | - |
| 6 | | mg/L | 4.0 | 0.42 | - | - | - |
| 7 | (Cu) | mg/L | 1 | | - | - | - |
| 8 | (pH) | - | 5.8~8.5 | 6.9 | - | - | - |
| 9 | | mg/L | 3 | 0.013 | - | - | - |
| 10 | | mg/L | 250 | 12.6 | - | - | - |
| 11 | | mg/L | 0.3 | | - | - | - |
| 12 | | mg/L | 0.05 | | - | - | - |
| 13 | | NTU | 0.5 | 0.05 | - | - | - |



한국수자원공사
Korea Water Resources Corporation

20-101359 8

4/4

.54851

1025 /

(063) 281-1248 /

(063) 281-1219

2020 05 27

